Walden's Ridge Utility District

3900 Taft Highway Signal Mountain, Tennessee 37377

Commissioners:

FFFFCTIVE:

28 APRII 2020

Manager:

General

FRANK M. GROVES, JR., PRESIDENT WEST J. ROBERT McKENZIE, VICE PRESIDENT DAVID J. FULTON, SECRETARY

RONALD

SERVICE LINE POLICY - AMENDED

The District requires the use of **COPPER OR TYPE A BLUE PEX** (GRADE A CROSS-LINKED POLYETHYLENE WITH ULTRA VIOLET PROTECTION, MUST BE BLUE COLOR) for all service lines from the meter to the dwelling, WHICH SHALL BE INSTALLED A MINIMUM OF THREE (3) FEET AWAY FROM ANY OTHER UNDERGROUND UTILITY.

The District will inspect the service line prior to installing the meter and allowing the service to become active.

The only exception the District will allow is if the property owner had ownership of the property prior to March 27, 2007 and signs a waiver relinquishing any right to a leak adjustment on the service line per the District's Leak Adjustment Policy. Once the waiver has been signed, then the property owner may use their choice of material for the service line which shall be a minimum of three (3) feet away from any other underground utility.

For any customer requesting a leak adjustment for their service line from the meter to the dwelling per the Leak Adjustment Policy, the customer will be granted one (1) adjustment per policy.

However, once this adjustment is given, COPPER OR TYPE A BLUE PEX MUST BE INSTALLED BEFORE ANOTHER LEAK ADJUSTMENT WILL BE GIVEN ON THE SERVICE LINE PER POLICY. When the service line is replaced, the customer must notify the District for a service line inspection before the customer will qualify for another leak adjustment.

20 AT INIL 2020		
Red.	2020 April 28	
Frank M. Groves, Jr., President	Date	
MANUSI	2020 April 28	
J. Robert McKenzie, Vice President	Date	
15 Nont	2020 April 28	
David J. Fulton, Secretary	Date	

(423) 886-2683 Office . (423) 886-1940 Fax Office Hours: 8:00 a.m. – 4:30 p.m. Monday through Friday